

# Certificate of Compliance

Certificate: 1430262

Master Contract: 187273

Project: 2162124

Date Issued: July 17, 2009

Issued to: CEDES AG  
Science Park  
CH 7302 Landquart  
SWITZERLAND

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only*



Issued by: G. Foulem

Authorized by: M.H.J.Hoendervangers  
Area Director, Europe



## PRODUCTS

CLASS – 2411 01 - ELEVATOR EQUIPMENT - Open and Enclosed - Elevator Electrical Equipment

CLASS – 2411 81 - ELEVATOR EQUIPMENT - CERTIFIED TO US STANDARDS.

CLASS – 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

CLASS – 3211 87 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus – CERTIFIED TO US STANDARDS

Slotted Light Switch Type GLS 126, GLS 126NT, GLS 151NT, GLS 126 NT-HCL rated 30 Vdc, 200 mA

Slotted Light Switch Type, GLS 126NT-MV, rated 60 Vdc, 200 mA.

Opto Electronic Information Sensor Type GLS 526, rated 30 Vdc, 600 mA, provided with 5 outputs, 100 mA each.

Opto Electronic Sensor Type PHSIS2 ( GLS 451/S ), rated 30 Vdc, 600mA, provided with 2 outputs, 200 mA each and 2 relay outputs, 80 Vdc 6W, 110Vac 110VA.

**Certificate:** 1430262

**Project:** 2162124



**Master Contract:** 187273

**Date Issued:** July 17, 2009

Note:

These units are Certified as components for use only in other Certified equipment where the suitability of the combination is determined by CSA International.

**APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No.0- M91- General Requirements

CSA Standard C22.2 No. 14- 05- Industrial Control Equipment

CAN/CSA-B44.1-04/ASME-A17.5-2004 - Elevator and Escalator Electrical Equipment

UL Standard UL 508, Seventeenth Edition - Industrial Control Equipment

**MARKINGS**

Submittor's name, tradename or M.C. number, type designation, electrical ratings, date coding, CSA Monogram and the Indicator NRTL/C or "C" and "US" may appear adjacent to the CSA Monogram are shown on a label on the enclosure

For Class No. 2411 01/81 the following marking shall appear:  
"CSA B44.1/ASME A17.5" adjacent to the CSA Mark.



## Supplement to Certificate of Compliance

Certificate: 1430262

Master Contract: 187273

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### Product Certification History

Project	Date	Description
2149836	July 17, 2009	Update to report to cover new types GLS 126 NT-HCL, GLS 126NT-MV.
1673967	July 14, 2005	Update to report to cover new types GLS151NT and PHSIS2
1490317	November 21, 2003	cCSAus - Update to -1430262 to cover alternate GLS 126NT
1430262	May 28, 2003	cCSAus - Certification of sensors Type GLS 126 and GLS 526